HOWARD LIGHTING PRODUCTS

3/29/2019

### Highbay Fluorescent - Six Lamp Low Profile Design



#### **Applications**

IN THE USA\*

Warehouse Manufacturing Facility Cafeteria Auditorium

#### **Features**

- Easy access ballast through removal of 2 screws and snap out reflector
- Access plate provides access to electrical wiring without the need to open the fixture
- Knock-outs for easy electrical wiring and assembly
- Factory Installed Occupancy Sensor option
- Lamp Installation option available
- Multiple power cord set options, (voltage, length, gage)
- Choice of 86% Standard Specular Aluminum Reflector, 95% Specular Enhanced Aluminum Reflector or 91% White Reflector
- Heavy Duty pre-painted steel construction
- Can be easily mounted by a single person
- Chain and V-Clip Hanging option
- Wire cable hanging option.
- UL Listed for Damp Locations


Project:	
Catalog#:	
Approved by:	

#### Description

HFLP series high-bay fluorescent fixture is a great energy saving alternative to traditional HID highbay fixtures. This fixture operates six lamps and comes equipped with Howard ballasts as a standard feature.

#### **Benefits**

- Energy Saving Compared to HID systems
- Exceptional Color Rendering
- High System Efficiency
- Long Lamp Life
- Instant On/Re-strike Capability
- Howard Ballast and Howard Lamp as a system is covered by Howard Industries Warranty
- Quality Lamp holders
- Computer Designed Reflectors
- System Tested, Designed, Approved, and Manufactured by Howard Industries in Mendenhall Mississippi.
- Compliant with Safety and performance standards.



Holes for WCH

<sup>\*</sup>Foreign and domestic components.



# Highbay Fluorescent

### Highbay Fluorescent - Six Lamp Low Profile Design

Project:	
Catalog#:	
Approved by:	

#### **Ordering Information**

Model Family	Reflector	No. of Lamps	Lamp Type/ Wattage <sup>(1)</sup>	CRI/CCT	Ballast	Input Volts	Factory Installed Options	Cordset Options	T B A	Pack.
HFLP	E	6	54	Α	PS	MV	00A	07	0	1
HFLP	E: Enhanced Specular Aluminum (95%) A: Specular Aluminum (86%) W: White reflective (91%)	6	T8 Lamps 28: F28T8 32: F32T8 T5 Lamps 28:F28T5 54: F54T5HO	A: No Lamps	SE: SBF High Eff <sup>(2)</sup> HE: HBF High Eff <sup>(2)</sup> LE: LBF High Eff <sup>(2)</sup> PS: PRS T5 P8: PRS T8 <sup>(2)</sup>	MV: 120-277v	000: No FIOs A: Occ Sensor <sup>(3) (4)</sup> I: Special Wiring Instructions	00: Standard Disconnect 01: 6' SJT 18/3, no plug 02: 10' SJT 18/3 L5-15, twist lock 120v 04: 10' SJT 18/3 L5-15, twist lock 120v 05: 6' SJT 18/3 L5-15twist lock 120v 06: 10' SJT 18/3 5-15non twist lock 120v 07: 6' SJT 18/3 S-15non twist lock 120v 07: 6' SJT 18/3 L7-15 twist lock 277v 08: 10' SJT 18/3 L7-15 twist lock 277v 11: 16/3, no plug specify length 17: 18/3, no plug specify length 22: 6' SJT 16/3 L7-20 twist lock 277v 23: 6' SJT 18/3 L6-15 twist lock 240v *Other cordsets available, consult customer service		I: Single

- (1) Lamp installation available.
- (2) High Efficiency ballasts are CEE Listed.
- (3) Occupancy Sensors should be used with programmed rapid start ballasts for maximum lamp life. Standard Occupancy Sensor requires neutral wired fixtures (ex. -120v or -277v). For phase-to-phase voltage applications (240v) advise Customer Service at time of request.
- (4) Bulk packaging is not available when occupancy sensor is ordered as a Factory Installed Option

SE	Standard Ballast Factor High Efficiency Instant Start T8 Ballast
HE	High Ballast Factor High Efficiency Instant Start T8 Ballast
LE	Low Ballast Factor High Efficiency Instant Start T8 Ballast
PS	Program Rapid Start T5 Ballast
P8	Program Rapid Start High Efficiency T8 Ballast


Sample Ordering Number: HFLP E 6 54 A PS MV 00A 07 I HFLP Series Highbay Fluorescent Enhanced Specular Aluminum Reflector 6-lamps (none installed) F54T5HO Program Rapid Start Ballast Multi-volt (120-277v) Factory Installed Occupancy Sensor 6' SJT 18/3 L7-15 twist lock 277v Cordset Single Packaging

RAPID SHIP MODEL AVAILABLE FOR NEXT DAY SHIPMENT

• HFLPA654APSMV0000001



#### **Field Installed Accessories**



HF-2CV (2 foot) HF-3CV (3 foot) Hanging Chain & V-clips



HF-WCH (~5 foot) Wire Cable Hanging Kit (2 pcs per kit)

Project:	
Catalog#:	
Approved by:	


	Ener	gy Cos	t Estir	mator	
		Existing	System	New S	ystem
		400W MH	Highbay	HFLPE6 High Eff Star Fluorescen	ndard Ballast
Hours burned per year	4368	Number of Fixtures	1	Number of Fixtures	1
Cost per kWh\$	0.12	Watts per Fixture (existing system)	458	Watts per Fixture (new system)	214
Energy	Cost	Energy used per year (existing system)	\$240	Energy used per year (new system)	\$112
Estima	ation	Energy sa year (per	ving per fixture)	\$128	3.00



(I)	
ŭ	
Š	
(I)	
0	
<u> </u>	
_	
正	
耳	
<u>证</u> >	
av F	
bav F	
bav F	
hbav F	
hbav F	
ahbav Fl	
iahbav Fl	

#### Photometric Data - 6 Lamp T8 (HFLPE632)

#### Candela Polar Plot



HFLPE632

Test Report: HFLP 6L T8 E 2012060.ies

Spacing Criteria (0-180): 1.28 Spacing Criteria (90-270): 1.46 Spacing Criteria (Diagnonal): 1.50

Maximum Candela =4811.13

Located At Horizontal Angle = 90, Vertical Angle = 10

#1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)

# 2 - Horizontal Cone Through Vertical Angle (10) (Through Max. Cd.)

# Project: Catalog#: Approved by:

#### **Luminaire Efficiencies\***

Reflector Type	T8
Enhanced Specular	88%
Specular	83%
White	84%

<sup>\*</sup>Luminaire efficiency is the ratio of light output emitted by the luminaire to the light output emitted by its lamps.

#### **Zonal Lumen Summary**

Zone	Lumens	%Lamp	%Fix
0-30	3738.67	21.50	24.40
0-40	6283.69	36.10	41.00
0-60	11466.81	65.90	74.90
0-90	15250.29	87.60	99.60
0-180	15309.84	88.00	100.00

#### Luminance Data (cd/Sq.m)

Angle In Degrees	Average 0-deg	Average 45-deg	Average 90-deg
45	9238	9392	8522
55	8872	8001	8656
65	8458	7700	7737
75	7986	5972	5362
85	6249	2264	1889


#### Coefficients of Utilization - Zonal Cavity Method

Effect	ive Floo	or Cavit	y Refle	ctance	0.20													
RC		8	0			7	0			50			30			10		0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	105	105	105	105	102	102	102	102	98	98	98	93	93	93	89	89	89	88
1	95	90	86	83	92	88	85	81	85	81	79	81	79	76	78	76	74	72
2	86	78	72	66	83	76	71	66	73	68	64	70	66	62	67	64	61	59
3	78	68	61	55	76	67	60	54	64	58	53	64	56	52	59	55	51	49
4	71	60	52	46	69	59	51	45	57	50	45	54	49	44	52	48	43	41
5	65	53	45	39	63	52	45	39	50	44	38	49	43	38	47	42	38	36
6	60	48	40	34	58	47	39	34	45	39	33	44	38	33	42	37	33	31
7	56	43	35	30	54	43	35	30	41	34	29	40	34	29	39	33	29	27
8	52	39	32	26	50	39	31	26	38	31	26	36	30	26	35	30	26	24
9	48	36	29	24	47	36	28	24	35	28	23	34	28	23	33	27	23	22
10	45	33	26	21	44	33	26	21	32	26	21	31	25	21	30	25	21	19

$\subseteq$
(II)
Ŭ
Ś
(I)
0
Š
_
正
叿
正 >
av Fl
av Fl
bav Fl
nbav Fl
hbav F
ahbav Fl
ighbav Fl

#### Photometric Data - 6 Lamp T5 (HFLPE654)

#### Candela Polar Plot



HEI PE654

Test Report: HFLP 6L T5 E 20120606.ies

Spacing Criteria (0-180): 1.28 Spacing Criteria (90-270): 1.42 Spacing Criteria (Diagnonal): 1.48

Maximum Candela = 9114.76

Located At Horizontal Angle = 90, Vertical Angle = 10

#1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)

# 2 - Horizontal Cone Through Vertical Angle (10) (Through Max. Cd.)

## Project: Catalog#: Approved by:

#### **Luminaire Efficiencies\***

Reflector Type	T5				
Enhanced Specular	92%				
Specular	88%				
White	88%				

<sup>\*</sup>Luminaire efficiency is the ratio of light output emitted by the luminaire to the light output emitted by its lamps.

#### **Zonal Lumen Summary**

Zone	Lumens	%Lamp	%Fix
0-30	7008.41	23.40	25.30
0-40	11625.93	38.80	42.00
0-60	20788.50	69.30	75.10
0-90	27649.77	92.20	99.80
0-180	27698.31	92.30	100.00

#### Luminance Data (cd/Sq.m)

Angle In Degrees	Average 0-deg	Average 45-deg	Average 90-deg
45	16898	16401	15511
55	16172	14217	13785
65	14578	12374	14689
75	13039	12108	12289
85	9002	4606	3087

#### Coefficients of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20																		
RC	80			70			50		30			10			0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	110	110	110	110	107	107	107	107	102	102	102	98	98	98	94	94	94	92
1	100	95	91	87	97	93	89	85	89	86	83	85	82	80	82	80	78	76
2	90	82	75	70	88	80	74	69	77	72	67	74	69	66	71	67	64	62
3	82	72	64	57	79	70	63	57	67	61	56	65	59	55	62	58	54	52
4	75	63	55	48	73	62	54	48	60	53	47	57	51	47	55	50	46	44
5	69	56	48	41	67	55	47	41	53	46	41	51	45	40	50	44	40	38
6	63	51	42	36	61	50	42	36	48	41	35	46	40	35	45	39	35	33
7	59	46	38	32	57	45	38	32	44	36	31	42	36	31	41	35	31	29
8	55	42	34	28	53	41	33	28	40	33	28	39	32	28	38	32	28	26
9	51	38	31	25	50	38	30	25	37	30	25	36	29	25	35	29	25	23
10	48	35	28	23	47	35	28	23	34	27	23	33	27	23	32	27	22	21